

7a

RCRA PERMIT
ADMINISTRATIVE RECORD
ITEM NUMBER
DATE: 8-23-89

Inspection: Regular Inspector: Lt. Matthew W. Johnson C/P/O E20/A7 Date: 8-23-89

Occ'y

Attention Haz-Mat Officer.

USEPA RCRA
3012552

F 6A (11/78) (TUMBLE
Ref. Technical Reference Manual 020 I 807C

INSPECTOR'S FIRE HAZARD REPORT

AUG 28 1989

Type of

Inspection: Regular Inspector: Lt. Matthew W. Johnson C/P/O E20/A7 Date: 8-21-89

Serial No.: 20-286 Area: III Index No.: 171-3 Time & Date of Fire: Not a fire

Address: 1515 W Garfield St Bldg 39

Occupancy: City Ice

SEND LETTER TO: (Responsible Party)

Mr. ~~Miss~~ ~~Ms~~ ~~Mrs~~.: Jack Roslyn

Title: owner Work Phone: 285-6500

Address: Pier 91 Box C-100 Zip: 98199

CC: ~~Yes~~ No

Mr. Miss Ms. Mrs.: n.a.

Title: n.a. Work Phone: n.a.

Address: n.a. Zip: n.a.

CC TO BLDG. DEPT.? ~~Yes~~ No

ATTN: Electrical Bldg. Inspectors Housing & Conservation

OCCUPANCY

Occ'y Class: 4 Certificate of Occ'y Posted? yes

No. of Units: n.s. Occupant Load: unknown

BUILDING

Year Const'd. 1938 Type of Construction: IV 1hour

No. of Stories: 2 Cellar () Basement ()

AUTOMATIC SPRINKLERS Wet () Partial () Dry (x) Complete (x)

OTHER FIRE EXTINGUISHING SYSTEMS:

SPECIAL INFORMATION AND/OR NOTES TO F.M.O.

Item No.	Designation	INSTRUCTIONS FOR ELIMINATION OF FIRE HAZARDS
1	210	Throughout building 39 and building 390.
2	102 a	Obtain a permit for the pallet storage in areas outside of building 39 & 390. (code 111, UFC 11.203.
2	102 b	Obtain a permit for the diesel storage tank located on the north side of building 39, outside. (code 791, UFC 79.103.)
3	xxx	To the diesel dispensing device located outside of building 39 on the north side:

Captain: [Signature] Chief: [Signature] B4-P F.M.O.: [Signature]